PRINTED: 03/09/2021
FORM APPROVED

Healthcare Licensing and Surveys

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	BH004	A. BUILDING: _____ B. WING _____	03/03/2021

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
WILLOW CREEK HOMES OF GILLETTE	2300 HARDER DRIVE GILLETTE, WY 82718

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
S 000	General Comments A Life Safety Code survey was conducted by Healthcare Licensing and Surveys on March 3, 2021. Wyoming Department of Health Rules and Regulations of Licensure of Boarding Homes, Chapter 7, Section 6, Building and Physical Plant. (o) All facilities exceeding one story in height shall be equipped with an automatic elevator. Facilities licensed prior to the effective date of these rules shall meet the Life Safety Code of the National Fire Protection Association that was in effect at the time the facility was licensed as a boarding home. Multi-storied wood frame buildings shall be sprinklered. The facility was a single story fully sprinklered building of Type V (111) construction built in 1989. The building was equipped with an automatic wet sprinkler building, and a zoned fire alarm system. The facility had a capacity of 14 licensed beds with a census of 4 residents. All references are based on the requirements of NFPA 101, Life Safety Code, New Board and Care, 1994 Edition, unless otherwise noted. Based on the findings of the survey team, it was determined the facility was in compliance with all requirements.	S 000		